

## CERTIFICATE OF CONFORMITY – FOAM CONCENTRATES

Certificate of conformity reference number: **KB 23/15**

Test specification: **EN 1568-1, -2 and -3 : 2008,**

Test report no.: **20141475/Fm 14**

Requested by: **Dafo Fomtec AB, Vindkraftsvägen 8, SE-135 26 Tyresö, Sweden**

Manufacturer: **Dafo Fomtec AB, Vindkraftsvägen 8, SE-135 26 Tyresö, Sweden**

Product name: **Fomtec® MB 5 -20  
MULTI PURPOSE FOAM**

Grade of foam concentrate: **Synthetic foam concentrate (S) according to annex A of EN 1568**

Test fire performance: **Extinguishing performance and burn-back resistance:**  
**Medium expansion foam according to EN 1568-1 with potable water / with simul. sea water:**  
**The requirements for medium expansion foam are met.**  
**High expansion foam according to EN 1568-2 with potable water / with simulated sea water:**  
**The requirements for high expansion foam are met.**  
**Low expansion foam according to EN 1568-3 with potable and with simulated sea water:**  
**III C / III C**

Freezing point: **- 21 °C**

Notes: **—**

Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for foam concentrates which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the foam concentrate the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

19<sup>th</sup> February 2015



Grad. Eng. Jürgen Dittrich  
Laboratory Manager



MPA Dresden GmbH  
Fuchsmühlenweg 6F  
09599 Freiberg  
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler  
Tel. +49(0)3731-20393-0  
Fax +49(0)3731-20393110  
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268  
Steuernummer: 220/114/03364  
USt-IdNr. DE291271296

Sparkasse Mittelsachsen  
Poststraße 1a  
09599 Freiberg  
IBAN DE68 870520003115024672  
BIC WELADED1FGX